

OFFICE OF ASSISTANT ENGINEER, PUBLIC HEALTH ENGG. SUB-DIVISION SEONI (M.P.)
DISTRICT WATER TESTING LABORATORY, SEONI (M.P.)
Address :- NEAR CIRCIT HOUSE POLICE LINE SEONI (M.P.)

WATER TESTING REPORT

Status of Sample	Drinking water and other	Unique Identification No.	—
Sender's name	प्राचार्य	Sender's letter no.& date	00 10/01/2024
Sender's address	वर्धमान पोदार लर्न स्कूल सिवनी (म.प्र.)	Year Ref. letter no.& date	198 10/01/2024
		Start Date Of Analysis	10/01/2024 to 11/01/2024
Quantity of Sample	—	DWTL receipt No.	—
Sample Collected by lab (Yes/No)	Yes	End Date Of Analysis	11/01/2024


Sample details:


S. No.	Block	Panchayat	Village	Habitation	Location
1	सिवनी	सिवनी	सिवनी	सिवनी	वर्धमान पोदार लर्न स्कूल


Physical & Chemical Test Report With Details of Parameters Their Test Methods, Units and Specifications as per BIS. (BIS 10500:2012)

S. No.	Colour Hezen unit (5-25)	Odour (Unobjectionable)	Taste (Agreeable)	Turbidity (1-5) (NTU)	pH (6.50 - 8.50) (at pH scale)	TDS (500-2000) (mg/l)	Alkalinity (200-600) (mg/l)	Chloride (250 -1000)(mg/l)	Fluoride (1.00 -1.50) (mg/l)	Nitrate (45 -45) (mg/l)	Sulphate (200-400) mg/l	Calcium as Ca++ (75-200) (mg/l)	Magnesium asMg (30-100) (mg/l)	Total Hardness (200-600) (mg/l)	Iron (0.30 -1.00) (mg/l)	Arsenic (0.01-0.01) (mg/l)	Total Coliform / E coli (0/100 ml)	Manganese (0.1-0.3) (mg/l)
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19
1	0	Agreeable	Agreeable	1.4	7.87	413.00	280.00	60.00	0.14	0.00	15.70	70.00	45.10	320.00	0.12	—	0/100 ml	0.00

Note - 1. Samples are not collected by us. **2.** Not to be produced at court of law. **3.** We do not take any responsibility for deviation in test result due to wrong collection of sample


Technical Manager
 District Water Testing lab
 P.H.E.Sub.Divi. Seoni


Quality Manager
 District Water Testing lab
 P.H.E.Sub.Divi. Seoni


Assistant Engineer,
 P.H.E. Sub Division,
 Seoni (M.P.)